

FRONT VIEW
(WITH DECORATIVE FRONT)

FRONT VIEW

SIDE VIEW

NOTES:

1. ALL DIMENSIONS ARE IN INCHES [MILLIMETERS].
2. FRONT AND REAR SERVICE ACCESS
3. CONDUIT ENTRY IS TOP OR BOTTOM OF UNIT.
4. UNIT WEIGHT IS 236 LBS [107 kg]
5. MBP IS SHIPPED WITHOUT SIDE PANELS.
   DURING THE INSTALLATION IT ADAPTS ONE SIDE PANEL OF UPS
6. INSTALLATION MUST COMPLY WITH ALL APPLICABLE NATIONAL AND LOCAL CODES

THIS DRAWING AND SPECIFICATIONS HEREIN ARE THE PROPERTY OF AMERICAN POWER CONVERSION AND SHALL NOT BE COPIED, REPRODUCED OR USED IN WHOLE OR IN PART, AS THE BASIS FOR THE MANUFACTURE OR SALE OF ITEMS WITHOUT WRITTEN PERMISSION FROM APC. THIS DRAWING IS BASED UPON LATEST AVAILABLE INFORMATION AND IS SUBJECT TO CHANGE WITHOUT NOTICE.

TITLE:	SMART-UPS VT 20-30kVA FLOOR MOUNT MAINTENANCE BYPASS PANEL WITHOUT POWER DISTRIBUTION PANEL 208V, 3PH, 20-30kVA MAIN MECHANICAL	DWG NO: SBPSU20K30FC1M1-MM1	REV. 1
PROJECT: SUBMITTAL DRAWINGS	SHEET 1 OF 5	DRAWN BY: JAYAPRAKASH	11/30/05
		CHECKED BY: M.LEPARD	11/30/05
		ENGINEER: L.ROZENBERG	11/30/05

APC®
AMERICAN POWER CONVERSION
132 FAIRGROUNDS RD
WEST KINGSTON, RI 02892



TOP VIEW (ENLARGED)



BOTTOM VIEW (ENLARGED)

NOTES:

1. ALL DIMENSIONS ARE IN INCHES [MILLIMETERS].
2. SOME STRUCTURAL DETAILS IN THESE VIEWS HAVE BEEN OMITTED FOR CLARITY.
3. INSTALLATION MUST COMPLY WITH ALL APPLICABLE NATIONAL AND LOCAL CODES.

THIS DRAWING AND SPECIFICATIONS HEREIN ARE THE PROPERTY OF AMERICAN POWER CONVERSION AND SHALL NOT BE COPIED, REPRODUCED OR USED IN WHOLE OR IN PART, AS THE BASIS FOR THE MANUFACTURE OR SALE OF ITEMS WITHOUT WRITTEN PERMISSION FROM APC. THIS DRAWING IS BASED UPON LATEST AVAILABLE INFORMATION AND IS SUBJECT TO CHANGE WITHOUT NOTICE.

TITLE: SMART-UPS VT 20-30kVA FLOOR MOUNT MAINTENANCE BYPASS PANEL WITHOUT POWER DISTRIBUTION PANEL 208V, 3PH, 20-30kVA TOP AND BOTTOM VIEWS	DWG NO: SBPSU20K30FC1M1-MM2	REV. 1	
	DRAWN BY: JAYAPRAKASH		11/30/05
	CHECKED BY: M.LEPARD		11/30/05
PROJECT: SUBMITTAL DRAWINGS	SHEET 2 OF 5	ENGINEER: L.ROZENBERG	11/30/05

APC®
AMERICAN POWER CONVERSION
132 FAIRGROUNDS RD
WEST KINGSTON, RI 02892



FRONT VIEW (DOOR REMOVED)

NOTES:

1. CONDUIT ENTRY IS TOP OR BOTTOM OF UNIT.
2. SBP CAN BE MECHANICALLY CONNECTED TO EITHER THE LEFT OR THE RIGHT SIDE OF THE UPS
3. INSTALLATION MUST COMPLY WITH ALL APPLICABLE NATIONAL AND LOCAL CODES

THIS DRAWING AND SPECIFICATIONS HEREIN ARE THE PROPERTY OF AMERICAN POWER CONVERSION AND SHALL NOT BE COPIED, REPRODUCED OR USED IN WHOLE OR IN PART, AS THE BASIS FOR THE MANUFACTURE OR SALE OF ITEMS WITHOUT WRITTEN PERMISSION FROM APC. THIS DRAWING IS BASED UPON LATEST AVAILABLE INFORMATION AND IS SUBJECT TO CHANGE WITHOUT NOTICE.

TITLE:	SMART-UPS VT 20-30kVA FLOOR MOUNT MAINTENANCE BYPASS PANEL WITHOUT POWER DISTRIBUTION PANEL 208V, 3PH, 20-30kVA INTERNAL VIEW-FRONT
PROJECT:	SUBMITTAL DRAWINGS
SHEET	3 OF 5
DWG NO:	SBPSU20K30FC1M1-ME
REV.	1
DRAWN BY:	JAYAPRAKASH 11/30/05
CHECKED BY:	M.LEPARD 11/30/05
ENGINEER:	L.ROZENBERG 11/30/05

APC®
AMERICAN POWER CONVERSION
132 FAIRGROUNDS RD
WEST KINGSTON, RI 02892



MIMIC DIAGRAM
(NORMAL OPERATING MODE)

THIS DRAWING AND SPECIFICATIONS HEREIN ARE THE PROPERTY OF AMERICAN POWER CONVERSION AND SHALL NOT BE COPIED, REPRODUCED OR USED IN WHOLE OR IN PART, AS THE BASIS FOR THE MANUFACTURE OR SALE OF ITEMS WITHOUT WRITTEN PERMISSION FROM APC. THIS DRAWING IS BASED UPON LATEST AVAILABLE INFORMATION AND IS SUBJECT TO CHANGE WITHOUT NOTICE.

TITLE:	SMART-UPS VT 20-30kVA FLOOR MOUNT MAINTENANCE BYPASS PANEL WITHOUT POWER DISTRIBUTION PANEL 208V, 3PH, 20-30kVA MIMIC DIAGRAM
PROJECT:	SUBMITTAL DRAWINGS
SHEET	4 OF 5
DWG NO:	SBPSU20K30FC1M1-MD
REV.	1
DRAWN BY:	JAYAPRAKASH 11/30/05
CHECKED BY:	M.LEPARD 11/30/05
ENGINEER:	L.ROZENBERG 11/30/05

APC®
AMERICAN POWER CONVERSION
132 FAIRGROUNDS RD
WEST KINGSTON, RI 02892



ISOMETRIC VIEW

THIS DRAWING AND SPECIFICATIONS HEREIN ARE THE PROPERTY OF AMERICAN POWER CONVERSION AND SHALL NOT BE COPIED, REPRODUCED OR USED IN WHOLE OR IN PART, AS THE BASIS FOR THE MANUFACTURE OR SALE OF ITEMS WITHOUT WRITTEN PERMISSION FROM APC. THIS DRAWING IS BASED UPON LATEST AVAILABLE INFORMATION AND IS SUBJECT TO CHANGE WITHOUT NOTICE.

TITLE:	SMART-UPS VT 20-30kVA FLOOR MOUNT MAINTENANCE BYPASS PANEL WITHOUT POWER DISTRIBUTION PANEL 208V, 3PH, 20-30kVA ISOMETRIC VIEW
PROJECT:	SUBMITTAL DRAWINGS
SHEET	5 OF 5

DWG NO:	SBPSU20K30FC1M1-ISO	REV. 1
DRAWN BY:	JAYAPRAKASH	11/30/05
CHECKED BY:	M.LEPARD	11/30/05
ENGINEER:	L.ROZENBERG	11/30/05

APC®
AMERICAN POWER CONVERSION
132 FAIRGROUNDS RD
WEST KINGSTON, RI 02892